

Bid 353

Northland Park Building 1 Mass Grading & Building 1 Pad Port KC

Questions 9-7-16

- 1). There are two RFP's for this project. One from Port KC and one from NorthPoint. There are items in each which contradict the other. For example, the Port KC RFP implies this will be a prevailing wage project and refers to a wage order. However, item 6 on page 2 of the NorthPoint RFP says, "Prevailing wage is not required for private mass grading and construction of the building pad." Which RFP take precedence over the other? Is the project a prevailing wage project? **NORTHPOINT RFP TAKES PRECEDENCE.**
- 2). If the project is a prevailing wage project, please provide Wage order referred in the Port KC RFP?

N/A

- 3). The Port KC RFP says the company will be required to comply with Port KC's affirmative action policy. Is there a set MBE and WBE usage % for the project? **INFO PROVIDED IN PORT KC EXHIBITS. POLICY FOUND [HERE](#). THE CONSTRUCTION WORKFORCE AFFIDAVIT CAN BE FOUND [HERE](#).**
- 4). The anticipated construction date listed in the NorthPoint RFP is Sept 26, 2016 Is this a realistic date for when we can plan to start the work or just an estimated date? **THIS IS THE ESTIMATED DATE. WORK WILL COMMENCE UPON RECEIPT OF PERMIT FROM KCMO. WE ANTICIPATE RECEIPT OF PERMIT APPROVAL BY 09-26-16.**
- 5). Do I understand correctly, we are simply doing the mass grading of the site including the grading of the building pad and the installation and removal of a dirt surcharge on the building pad, is that correct? **CORRECT**
We do not include sub-grading for curbs, pavements and sidewalks, is that correct? **CORRECT**
We do not include site finishing grading once the building is constructed, is that correct? **CORRECT**
Once the surcharge is removed, the detention ponds are constructed, we would be complete with our contractual requirements, is that correct? **CORRECT**
- 6). Paragraph 1.1.A.3 of the NorthPoint RFP says, "The scope of design work to be furnished by the Contractor shall included additional design, if any, necessary to provide a complete turnkey scope of construction work." What design work would we have to provide? **NO ADDITIONAL DESIGN WORK IS ANTICIPATED**
- 7). Will an addendum be issued removing the requirements of paragraph 1.5 of the NorthPoint RFP since the mass grading work design is suppose to be 100% complete? **ADDITIONAL DESIGN WORK IS NOT ANTICIPATED**
- 8). Is the intent of the drawings and scope of work that the site be a balanced site condition such that all material necessary for construction, including the building surcharge be obtained from the site and no fill material will have to be hauled in or excavated material haul out of the project? **THE INTENT IS FOR A BALANCED SITE – ANY EXCESS MATERIAL IS TO BE LEFT ONSITE FOR USE IN FUTURE BUILDING PAD CONSTRUCTION – ANY ADDITIONAL MATERIAL REQUIRED TO BRING THE SITE TO GRADE OR TO COMPENSATE FOR SHRINKAGE OR CONSOLIDATION IS THE RESPONSIBILITY OF THE CONTRACTOR**
- 9). Paragraph 2.4 of the NorthPoint RFP says for the Contractor to include any retaining walls or slope reinforcement needed to achieve the grades and critical elevations shown on the plan. Is this a requirement

for the next contractor or will the mass grading contractor have to plan on the construction of retaining walls? If so where at? **RETAINING WALLS ARE NOT ANTICIPATED TO BE REQUIRED FOR THE MASS GRADING SCOPE OF WORK.**

- 10). Paragraph 2.5 of the NorthPoint RFP discussed temporary parking, storage and haul roads. Is this requirement only for our work or it is suppose to include the building contractor's work? We will not need any temporary rocked areas other than the construction entrance. Are there any rocked areas you want us to included in our proposal? If so, how big of an area, how thick and type of rock. **THIS NOTE IF FOR THIS SCOPE OF WORK ONLY. PROVIDE AS SHOWN ON THE DRAWINGS. CONSTRUCITON ENTRANCE TO REMAIN UPON COMPLETION OF WORK.**
- 11). Your minimum insurance requirement has umbrella excess liability of \$10,000,000 aggregate. Does the grading contractor need this much of a limit or can it be less? **PROVIDE PROPOSED INSURANCE TERMS IN RFP RESPONSE.**
- 12). What is the anticipated date of the Corps of Engineers Permit to allow entrance into the Agricultural Wetlands? Is there any work that is suppose to take place in the two Agricultural wetlands? They appear in all the plan sheets to surrounded by silt fence and left alone, is that correct? **ANTICIPATED DATE OF CORPS APPROVAL IS 10/07. THE LARGER OF THE TWO AREAS IS WITHIN THE GRADING AREA. THE SMALLER OF THE TWO IS INTENDED TO BE LEFT ALONE. SILT FENCE AROUND THIS AREA TO REMAIN AT COMPLETION OF WORK.**
- 13). Do we include all of the ECS Phase 4 ground cover work as shown on sheet C105? There is work, for example, the Rip-Rap Flumes that would appear to be installed after the parking lots are installed which leads me to believe we will be on site until the building is completed, is that correct? **RIP RAP FOR FLUMES ARE ALL INTENDED TO BE FUTURE AND PART OF THE BUILDING PACKAGE. EXCLUDE ANY WORK THAT WILL NOT BE PERFORMED SEQUENTIALLY OR CONCURRENTLY WITH THE MASS GRADING AND SURCHARGE.**
- 14). Can the sediment basin clay liner be installed during the construction of the basins or does it need to be installed at the end of the project cycle? **CLAY LINER CAN BE INSTALLED DURING CONSTRUCITON OF THE BASINS. IT WILL NEED TO BE MAINTAINED DURING THE REMAINDER OF THE GRADING WORK UNTIL THE SITE IS TURNED OVER TO THE GENERAL CONTRACTOR.**
- 15). Please provide exhibits A, B, & C as referenced in the Port KC RFP along with the bid form. **PROVIDED BY PORT KC.**
- 16). In the Port KC RFP there is a reference to a Scope of Work Statement. Is this something that will be coming or is it just referring to the plans and specs. as the scope of work. **IT IS REFERENCING THE PLANS AND SPECS.**
- 17). When silt is removed from the basins, can it be left on site or does it need to be hauled off site? **SILT CAN REMAIN ONSITE NEAR THE TOPSOIL STOCKPILE AREA.**